

Building Renewal Grant Application

Initial Submission Date: 5/14/2014 2:19:00 PM

Application ID: 1213

Resubmittal Date:

Please provide as much of the requested information as possible. SFB staff will assist in developing required information that is not currently available.

District Name: Yuma Union High School District

Superintendent: Antonia Badone

Contact Person: David Hylland

Contact Phone Number: (928) 502-4637

Contact Email: dhylland@yumaunion.org

School Site: San Luis High School

Buildings: 9999 School Wide

Application Title: Underground chilled water leak

Description of Problem

Please include a detailed description of the issues, as well as a description of and a copy of any professional studies, citations or reports from government entities, recommended solutions, and any cost information or estimates. If additional space is needed, please attach.

Locate and repair underground leak in closed loop chilled water system. Leak has been confirmed based on flow meter at make-up water line at central plant (2000+ gpd). All piping is underground, under concrete with no sign of water coming to surface. District has made numerous attempts to locate without success.

SunState Mechanical has provided a quote for \$2000 to travel to Yuma and perform acoustical locating services (see attached).

Project Category: HVAC

Are any of the above-described issues in buildings or part of buildings that are leased to another entity, including a district sponsored charter school? N

Available Funding

Amount of Local funds planned for this project	\$0.00
--	--------

Please outline any associated insurance coverage.

District has no financial resources to investigate or repair this issue. District personnel have core-drilled concrete and utilized probes and other means to attempt to locate issue.

District hired Encompass to perform locating services previously (see attached report).

Liaison: Cruse

pcruse@azsfb.gov

602-364-1193

Building Renewal Grant Application

Superintendent Printed Name

Superintendent Signature

Date